



# TOWN OF HILLSBORO BEACH, FLORIDA

1210 Hillsboro Mile  
Hillsboro Beach, Florida 33062

(P) 954-427-4011  
(F) 954-427-4834

## RFP No. 2021-001

### Replacement of Beach Pump Station Roof

#### Addendum No. 1 and Request for Information (RFI)

1. **Question: Alternate cost for all copper flashing i.e. Drip edge, Eve closure and ridge metals**

**Answer:** The Town has decided that "Copper" material shall be used for all ridge metals i.e., drip edges and eve closures

2. **Question: Soffit replacement - Is this in the contract or do we leave it out?**

**Answer:** The Town has decided that the Soffit shall be replaced on the entire structure and any underlying damaged wood shall be replaced.

3. **Question: Lightning protection - there is lightning protection on the building - what do you want us to do with it?**

**Answer:** The lighting protection is to be removed and NOT replaced.

4. **Question: It was noted that the roofing tile on Town Hall was a lighter grey color and not white. Do you wish to change the desired roof tile color to light grey instead of white?**

**Answer:** Yes. The roofing tile colors are to match exactly what is on the roof at Town Hall.

Sincerely,  
Mac Serda, ICMA-CM  
Town Manager



2-18-2021